



Code Enforcement Office

Compliant Structure List

Prior to utilities being connected, the Code Officer inspects all structures for compliance:

- Operable smoke detectors in each bedroom area, with at least one on each floor
- Cover plates on switches and receptacles
- Water heater must be vented and pressure relief piped to outside (pipe must be 3/4")
- No uncapped gas pipes
- Handrails are required for porches and steps when deck or entrance is over 30" high
- Outside doors and windows in place and working
- Correct street address on structure and visible from street
- Generally sanitary conditions in house
- Clean and sanitary exterior and yard